



CERTIFICATE

No. Z10 08 04 62386 004

Holder of Certificate: BECKHOFF Automation GmbH
Eiserstraße 5
33415 Verl
GERMANY

Factory(ies): 62386

Certification Mark:



Product: Safety components

Model(s): KL 6904

Parameters:
Supply voltage: 24VDC (-15%/+20%)
Power dissipation: 2W
Protection class: IP 20

Tested according to:
98/37/EC Machinery Directive
EN 61508-1:2001 (SIL1-3)
EN 61508-2:2001 (SIL1-3)
EN 61508-3:2001 (SIL1-3)
EN 954-1:1996 (Cat 4)
DIN EN ISO 13849-1:2006 (Cat 4, PL e)
EN 81/AC:1999 (as applicable)
EN 13243:2004 (as applicable)
DIN EN 61000-6-2:2002
DIN EN 61000-6-4:2002

The listed product was tested on a voluntary basis and complies with the relating standards or directives. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.: BV82168T

Peter G. Weiß

Date, 2008-04-17

Page 1 of 1

